

Anantapur II REZ Transmission Limited

Office Address: - DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Gurugram, Haryana-122008

NOTICE

((Under sub-section (2) of Section 15 of the Electricity Act, 2003)

1. Anantapur II REZ Transmission Limited, having its office at DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Gurugram, Haryana-122008, which is incorporated under the Companies Act, 1956 has made up an application before the Central Electricity Regulatory Commission, New Delhi under sub section (1) of Section 15 of the Electricity Act, 2003 for grant of transmission license in respect of the transmission lines, sub stations and other assets, the details of which are given

Sl. No	Name of the line/substation (location)	Line Length/Capacity	Estimated	Commissioning Completion Cost	Remarks Schedule
1.	Establishment of 4x1500 MVA, 765/400 & 6x500 MVA, 400/220 kV Ananthapuram-II Pooling Station near Kurnool, Andhra Pradesh along with 2x330 MVAR (765 kV) bus reactors at Ananthapuram-II PS with provision of two (2) sections of 4500 MVA each at 400 kV level.	<ul style="list-style-type: none">• 765/400 kV, 1500 MVA, ICTs – 4 Nos. (13x500 MVA incl. 1 spare unit)• 765 kV ICT bays – 4 Nos.• 400 kV ICT bays – 4 Nos.• 400/220 kV, 500 MVA, ICTs – 6 Nos.• 400 kV ICT bays – 6 Nos.• 220 kV ICT bays – 6 Nos.• 765 kV line bays – 4 Nos. (at Ananthapuram-II PS for termination of Ananthapuram-II – Davanagere and Ananthapuram-II – Cuddapah 765kV D/C lines)• 765 kV, 330 MVAR Bus Reactor – 2 Nos.• 765 kV Bus Reactor bays – 2 Nos.• 220 kV line bays – 6 Nos.• 220 kV Bus Sectionalizer: 1 set• 220 kV Bus Coupler (BC) Bay – 2 Nos.• 220 kV Transfer Bus Coupler (TBC) Bay – 2 Nos	₹ 4,486.42 million per annum	24 months	
2.	Ananthapuram-II – Davangere 765 kV D/C line with 240 MVAR SLR (convertible) at Ananthapuram-II end on both circuits.	<ul style="list-style-type: none">• ~ 150 km• 765 kV line bays – 2 Nos. (at Davanagere PS)• 765 kV, 240 MVAR SLR at Ananthapuram-II PS – 2 Nos. (7x80 MVAR including 1 switchable spare unit)			
3.	Ananthapuram-II – Cuddapah 765 kV D/C line with 330 MVAR SLR (convertible) at Ananthapuram-II end on both circuits	<ul style="list-style-type: none">• ~ 200 km• 765 kV line bays – 2 Nos. (at Cuddapah)• 765 kV, 330 MVAR SLR at Ananthapuram-II PS – 2 Nos. (7x110 MVAR including 1 switchable spare unit for both bus reactor and line reactor)			
4.	+300 MVAR STATCOM at Ananthapuram-II PS along with 2x125 MVAR MSR	<ul style="list-style-type: none">• 400 kV bay – 1 No			

2. Complete application and other documents filed before the Commission are available on the website <https://www.sterlitepower.com/> for access of any person. The application can also be inspected at the office of the company at DLF Cyber Park Tower B, 9th Floor, Udyog Vihar Phase-III, Sector-20, Gurgaon, Haryana-122008 with Mr. T. Amarendranath Reddy or Office of the Commission in accordance with the procedure specified by the Commission.
3. Objections and suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 6th, 7th & 8th Floors, Tower B, World Trade Centre, Nauroji Nagar, New Delhi- 110029, with a copy of the objection(s)/suggestion(s) to the applicant or its authorized agent within 15 days of publication of the notice in the newspaper.

T. Amarendranath Reddy
Director- Business & Regulatory
Anantapur II REZ Transmission Limited

Place: Gurgaon
Date: 11.04.2025